


Practical sound absorption coefficient, weighted sound absorption coefficient, and absorption class according to EN ISO 11654:1997 $\alpha_w = 0,80$ absorption class: B



Tested module size: 1,2 x 1,8 m.